



Product Service

Attestation of Conformity

No. N8A 124444 0001 Rev. 00

Holder of Attestation: Fiorini Industries S.r.l.

via Zampeschi, 119
47122 Forlì
ITALY

**Product: Heat pumps
(Air Source Heat Pump)**

Model(s): FURIA 6M R290, FURIA 8M R290, FURIA 12M R290

Parameters:

Rated Voltage:	220-240V~
Rated Frequency:	50Hz
Rated Power:	FURIA 6M R290: 3500W, FURIA 8M R290, FURIA 12M R290: 5400W
Rated Current:	FURIA 6M R290: 15,0A, FURIA 8M R290, FURIA 12M R290: 25,0A
Protection Class:	Class I
Degree of Protection:	IPX4
Refrigerant:	R290

Tested according to: EN 60335-1:2012/A15:2021
EN 60335-2-40:2003/A13:2012
EN 62233:2008

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64111230439501

Date, 2024-02-29

(Sam Yang)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.